(C1)

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 140037 PIN# 3793-54-3772 DATE 4 June 07

OWNER OR APPLICANT Capote Builders & Development Co. PHONE: Business 704-483-7313 Home

ADDRESS 5426 Capote Rd.

LOCATION Sharon Schurch Rd. Turn onto Mock Mill Rd. on Rt.

SUBDIVISION Augusta Groves BLOCK / SECTION 2 LOT 23 LOT AREA 0.52 AC. SITE CLASS. P3 DESIGN FLOW 360gpd L.T.A.R. 0.3 g/ft²/d.

Septic Tank: 1000 Gallons; STB 55 Date 10-1-07

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet = 1200 Linear Feet 300

No Lines 5 Trench Width 36" Max Trench Bottom Depth 36"

☑ New System ☐ Repair ☐ Expansion System Type: I (II) III IV V VI

System Description: 25% Reduction

Repair System Description: 25% Reduction Amp

Maintenance Agreement Required: ☐ Yes ☐ No

Gravel Depth ☑ Gravity ☐ Pressure

☐ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Persons

☐ Business No. Employees

☐ Other

Water Supply: ☐ Individual ☑ Public ☐ Community

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: Follow contour

Comments/Conditions: Blue Poly Sock Septic Tank Effluent

INITIAL SITE SKETCH

See Attached Site plan.

AS-BUILT SKETCH

Line #1 13 panels

2 14 panels

3 16 panels

4 16 panels

5 16 panels.

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☑ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date

Improvement Permit by: , R.S. date 11 June 07

Authorization to Construct by: , R.S. date 11 June 07

Installed by: C-M

Operation Permit by: , R.S. date 08 19 March 08

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

250
199
PB 48-73
TITLEIST DR
221
890
1 inch equals 50 feet
21
110
216
210
20
110
22
930
210
123
125
BIG BERTHA DR
210
19
110
107
23
107
210
107
125
N
E
S
W