IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 128524 PIN# 3793-55-0346 DATE 6-17-05

OWNER OR CONTRACTOR JOHN CRAVER PHONE: Business 704-534-7000 Home (704) 663-2220

ADDRESS 130 LAZY LN. MOORESVILLE NC 28117

LOCATION I-40W (TL) SHARON SCHOOL (TL) MOCK MILL PROPERTY 1 MILE ON RT.

SUBDIVISION AUGUSTA GREENS BLOCK / SECTION ____ LOT 2 LOT AREA 0.568 SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. 0.30 GPD/FT²

Septic Tank: 1000 Gallons; STB 1012 Date 1-14-05

Pump Tank: ____ Gallons; PT ____ Date ____

Pump Make: ____ Model ____ Serial No. ____

Nitrification Field: No. Fields 1 Square Feet 1600 Linear Feet 400

No Lines FOUR (4) Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☐ Repair System Type: I, (II) III IV, V, VI

System Description: GRAVITY 25% REDUCTION

Repair System Description: LP PPBPS 50% REDUCTION

Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms ____

☐ Business No. Employees ____

☐ Other ____

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☑ Public ☑ Community

Comments:/Conditions: ① LSS USING E-Z FLOW FOR 25% REDUCTION INITIAL ② INSTALL SYSTEM ACCORDING TO LSS ~~REQUEST~~ SPECIFICATIONS

Comments:/Conditions: TIFF TITE FILTER MARKER

85

100

115


100

INITIAL SITE SKETCH

SEE ATTACHED SITE PLAN

BY MICHAEL ATHANAS, LSS

AS BUILT SKETCH



- OWNER AUTHORIZES CHANGES
- INSTALL IN FILTRATORS

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Tina Johnston date 6-20-05 Installed by: A-1 BACKHOE

Improvement Permit by: Christopher M. Sterrett LSS date 6-17-05 Operation Permit by: [signature] date 7-11-05

Authorization to Construct by: Christopher M. Sterrett LSS date 6-20-05 Existing System Inspection by: ____ date ____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK