IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Steven Nash Jr. DATE 10/2/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70 W. Past Millers Fabric Shop T.R. into Deer Trail Acres. House on L. Near end of Rd. S. R. No. _____

SUBDIVISION NAME Deer Trail Acres LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 2 ½ Acres


Character & Porosity of Soil Prov Suitable

Percolation Rate _____

Topography Steep Slope

Depth to Water Table Low

Rock or other impervious formations yes • Spring



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 168 Linear Ft. 288
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )
Spring

Installed by Hoke Septic Tank Co

IMPROVEMENTS PERMIT BY _____

COMMENTS: Water from house and all surface water possible should be diverted away from septic Tank + lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 10/2/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold