13697. 41693

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR DARYL BYERS DATE 12-12-91 PERMIT NO. 8H-A-40A

PHONE: Business _____ Home _____

LOCATION Hwy 70W - 3 miles past White Oaks - T.R. into dev. - stay straight & end of pavement & bear @ on pavement - stay on pavement & house on Flat Rock Curve S.R. No.

SUBDIVISION NAME DEER TRAIL ACRES. LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Plus storage bldg. with a toilet.


No. Bedrooms 3 No. Bathrooms 2.5

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Gray - Suitable.
Percolation Rate 4 gal/sq. ft.
Topography 2-8%
Depth to Water Table 10'+
Rock or other impervious formations scattered rock.

Lot Area 1 9 acres.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Forest Shuford

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS Tank sets approx 15' from foundation.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 12-12-91.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold