DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY: PENDER

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: AMERICA'S HOME PLACE INC
ADDRESS: 168-D NORTH STANDON BLVD, MUL, 28119
PROPOSED FACILITY: 3 BR H
PROPOSED DESIGN FLOW (.1949): 360
LOCATION OF SITE: AUGUSTA GREENS LOT 54
APPLICATION DATE 3-21-07
DATE EVALUATED: 4-18-07
PROPERTY SIZE: 1.292 ACRES
PROPERTY RECORDED:
WATER SUPPLY: ☒ Private ☒ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	AUGER 6%	0-17	~~ABK~~ C	FR ~~SOFT~~	RELIC MOTTLING DUE TO QUARTZ @ 17"+				PS 0.25
		17-48	SBK SC	FR ~~SOFT~~					
2	PIT 6%	0-19	ABK C	FR ~~SOFT~~	RELIC MOTTLING DUE TO QUARTZ @ 19"+				PS 0.25
		19-48	SBK SC	FR ~~SOFT~~					
3	AUGER 4%	0-29	ABK C	FR ~~SOFT~~	RELIC MOTTLING DUE TO QUARTZ @ 29"+				PS 0.25
		29-48	SBK SC	FR ~~SOFT~~					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	~~II~~	III
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HODNICK
OTHER(S) PRESENT: CHAD

COMMENTS: