DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET 1 OF 1
PROPERTY I.D.#: 8H-5-A-14
DATE: 11-6-95
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: KRISTOPHER LADELL MEREDITH OWNER ✓ AGENT: PHONE: 878-0706
ADDRESS: 508 CAMELOT DR. APPLICATION DATE: 10-25-95 DATE EVALUATED 11-6-95
STATESVILLE, NC 28677 PROPOSED FACILITY: 3BR D/W MH
PROPERTY SIZE: 115' x 174'
LOCATION OF SITE: HOKE SUBDIVISION, LOT # 14
WATER SUPPLY: On-site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	H	0-48	c	WFSBK	1:1/Fi/s/p			.1942 Wetness Cond. 5
	4%							.1943 Depth/.1956 Sapr. 5
								.1944 Restrictive Hori. 5
								.1948 Profile Class. PS
								Profile LTAR 0.25
2	H	0-48	c	WFSBK	1:1/Fi/s/p			.1942 Wetness Cond. 5
	4%							.1943 Depth/.1956 Sapr. 5
								.1944 Restrictive Hori. 5
								.1948 Profile Class. PS
								Profile LTAR 0.25
3	H	0-30	sc	WFSBK	1:1/FR/s/sp	—	WET	.1942 Wetness Cond. 5
	4%	30-48	c	WFSBK	1:1/Fi/s/p			.1943 Depth/.1956 Sapr. 5
								.1944 Restrictive Hori. 5
								.1948 Profile Class. PS
								Profile LTAR 0.3
4	H	0-32	sc	WFSBK	1:1/FR/s/sp	—	WET	.1942 Wetness Cond. 5
	6%	32-48	c	WFSBK	1:1/Fi/s/p			.1943 Depth/.1956 Sapr. 5
								.1944 Restrictive Hori. 5
								.1948 Profile Class. PS
								Profile LTAR 0.3

AVAILABLE SPACE (.1945) PS OTHER FACTORS (.1946) NONE SITECLASSIFICATION (.1948) PS
SYSTEM TYPE PPBPS, GRAVITY - FED LONG-TERMACCEPTANCE RATE(S) 0.25
EVALUATED BY: STEVE HENDRICK OTHER(S) PRESENT: BRAD STALLARD, KRIS MEREDITH
COMMENTS: SUB-SURFACE INTERCEPT DRAIN REQUIRED

0011123