04306

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JAMES ELMORE DATE 3-25-86 PERMIT NO.

PHONE: Business Home

LOCATION Mack Mill Rd - off Bethel Church Rd. - go approx. 2.5 miles
on dirt rd. - 1st lot on L.

SUBDIVISION NAME MACK MILL PARK LOT NO. 76 S. R. No. SECTION OR BLOCK NO.


House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2-3 No. Bathrooms 1-2

| | | |
|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) |
| Auto. Dishwasher | Yes ( ) | No (✓) |
| Auto. Wash. Machine | Yes (✓) | No ( ) |
| Site Suitable | Yes (✓) | No ( ) |

Lot Area Ample

Character & Porosity of Soil Fair - Suitable.
Percolation Rate 2 Bpi / 30 M.
Topography Slight slope to R.
Depth to Water Table 10'+
Rock or other impervious formations Rock encountered.




Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 720
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Kenneth Chaffin

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS:

CERTIFICATE OF COMPLETION BY Steve Brown DATE 3-25-86

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold