DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET 2 OF 2
PROPERTY I.D.#:
DATE: 2-7-95 / 2-14-95
COUNTY Iredell

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Junior Sharpe
ADDRESS:
OWNER AGENT PHONE:
APPLICATION DATE: DATE EVALUATED 2-7-95
PROPOSED FACILITY: 3 Bedroom SW MH
PROPERTY SIZE:

LOCATION OF SITE: Deer Trail Acres Rd
WATER SUPPLY: On-site Well ✓ Comm. Well Public Other EVAL METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
5	2-3%	0-3"	cl	gr	1:1 / fr			.1942 Wetness Cond. - 5
	L	3"-29"	c	sbk	1:1 / fi			.1943 Depth/.1956 Sapr. - 36" P.S.
		29"-36"	C/sap.	sbk/m	1:1 / fi			.1944 Restrictive Hori. - NA
		36"-48"	Sap.	m	1:1 / fr			.1948 Profile Class. - P.S
								Profile LTAR - .35
6	2-3%	0-4"	cl	gr	1:1 / fr			.1942 Wetness Cond. - 5
	L	4"-28"	c	sbk	1:1 / fi			.1943 Depth/.1956 Sapr. - 36" P.S.
		28"-36"	C/sap.	sbk/m	1:1 / fi			.1944 Restrictive Hori. - NA
		36"-48"	Sap.	m	1:1 / fr			.1948 Profile Class. - P.S.
								Profile LTAR - .35
7 2-14-95	3-5%	0-5"	cl	gr	1:1 / fr			.1942 Wetness Cond. - 5
	L	5"-30"	c	wsbk	1:1 / fi			.1943 Depth/.1956 Sapr. - 36" P.S.
		30"-38"	C/sap.	wsbk/m	1:1 / fr			.1944 Restrictive Hori. - NA
		38"-48"	Sap.	m	1:1 / fr			.1948 Profile Class. - P.S
								Profile LTAR - .3
8 2-14-95	3-5%	0-4"	cl	gr	1:1 / fr			.1942 Wetness Cond. - 5
	L	4"-24"	c	wsbk	1:1 / fi			.1943 Depth/.1956 Sapr. - 36" P.S.
		24"-36"	C/sap	wsbk/m	1:1 / fr			.1944 Restrictive Hori. - NA
		36"-46"	Sap.	m	1:1 / fr			.1948 Profile Class. - P.S
								Profile LTAR - .35

AVAILABLE SPACE (.1945) 5 OTHER FACTORS (.1946) SITE CLASSIFICATION (.1948) P.S.

SYSTEM TYPE conventional / gravity Ad LONG-TERM ACCEPTANCE RATE(S) .3 gpd/ft²

EVALUATED BY: Michael J. Dunn OTHER(S) PRESENT: Mark Frye

COMMENTS:

0017 22