DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM


OWNER:
ADDRESS:
APPLICATION DATE 2-21-17
PROPOSED FACILITY: PROPOSED DESIGN FLOW (.1949):
DATE EVALUATED: 2-21-17
LOCATION OF SITE:
PROPERTY SIZE:
PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
1	NS 7%	0-6	6 r SCL	fr SE	N/A	19"	N/A	N/A	PS Dup 1.1
		6-19	ABK C	fi SE					
		19-37	mass CR	vfi N/P					
2	NS 10%	0-48	SBK C	fi SE	N/A	48"	N/A	N/A	PS 1.25
P 3	NS 10%	0-6	6 r SCL	fr SE	N/A	36"	N/A	N/A	PS 1.25
		6-36	SBK C	fi SE					
		36-48	mass CR	vfi N/P					
P 4	NS	0-6	6 r SCL	fr SE	N/A	32"	N/A	N/A	PS Dup 1.1
		6-32	SBK C	fi SE					
		32-48	mass CR	vfi N/P					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	II	I
Site LTAR	1.3	1.1 Dup

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: LJ Snow
OTHER(S) PRESENT:

COMMENTS:


BLD 6
1
Propose
2
3
4
Volt Power