HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: Indell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Michael Scott Caskaddon OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 8-31-94
PROPOSED FACILITY: 2 Bedroom SW MH
PROPERTY SIZE:
LOCATION OF SITE: Moff Park Rd.
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1		0-2"	cl	gr	fr	.1942 WETNES CONDITION - S
		2"-37"	c	sbk	fi	.1943/.1956 SAPROLITE - 40" P.S.
		37"-40"	c/sap	wsbk/m	fi	.1944 RESTRICTIVE HORIZON - NA
		40"-48"	sap.	m	fr	.1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .33
2		0-1"	l	gr	fr	.1942 WETNES CONDITION - S
		1"-34"	c	sbk	fi	.1943/.1956 SAPROLITE - 39" P.S.
		34"-39"	c/sap.	wsbk/m	fr	.1944 RESTRICTIVE HORIZON - NA
		39"-48"	Sap	m	fr	.1948 PROFILE CLASSIFICATION - P.S.
						PROFILE LTAR - .33
3		0-2"	l	gr	fr	.1942 WETNESS CONDITION - S
		2"-32"	c	sbk	fi	.1943/.1956 SAPROLITE - 40" P.S.
		32"-40"	c/sap	sbk/m	fr	.1944 RESTRICTIVE HORIZON - NA
		40"-48"	sap.	m	fr	.1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .35
4		0-3"	cl	gr	fr	.1942 WETNESS CONDITION - S
		3"-36"	c	sbk	fi	.1943/.1956 SAPROLITE - 40" P.S
		36"-40"	c/sap	wsbk/m	fi	.1944 RESTRICTIVE HORIZON - NA
		40"-48"	sap.	m	fr	.1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .33
5		0-4"	l	gr	fr	.1942 WETNESS CONDITION - S
		4"-36"	c	sbk	fi	.1943/.1956 SAPROLITE - [redacted] 48" P.S.
		36"-48"	c/sap.	wsbk/m	fi	.1944 RESTRICTIVE HORIZON - NA
						.1948 PROFILE CLASSIFICATION - P.S.
						PROFILE LTAR - .33

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): P.S. SITE LONG-TERM ACCEPTANCE RATE: .33 gpd/ft²
OTHER FACTORS(.1946) SYSTEM TYPE
EVALUATED BY: Michelle Dennis OTHER(S) PRESENT: Scott Caskaddon
COMMENTS:

DRAFT