11482.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR KEITH GOFORTH DATE 7-20-90 PERMIT NO. SH-A-80.

PHONE: Business _____ Home _____

LOCATION Mack Mill Rd. Statesville Rt. - approx. 2.5 miles Rt. on dirt rd. on Dreasend S. R. No. _____

SUBDIVISION NAME MACK MILL PARK LOT NO. 53-60. SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other ADD ON TO MOBILE HOME LATER.

No. Bedrooms 2 No. Bathrooms 1.5

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 200' x 300'

Character & Porosity of Soil Clay Suitable.

Percolation Rate 30 Min/Inch

Topography 2-10% Slope

Depth to Water Table 10'+

Rock or other impervious formations None observed.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Size of Tank 1000 Gals.


Nitrification Field:

No. of Lines 4

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )



Plot of System

Installed by Wes Lytton

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 7-20-90.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold