HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Chris Davidson OWNER: _ AGENT: _ PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
_____ PROPOSED FACILITY: _____
_____ PROPERTY SIZE: _____
LOCATION OF SITE: Mock Park Lot 88
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	1941 (a)(1) TEXTURE	1941 (a)(2) STRUCTURE	1941 (a)(3) MINERALOGY	
1	Linear 8 to 10%	0 to 4	L	GR		1942 WETNESS CONDITION - N/A
		4 to 30	C	ABK	1:1	1943/ 1956 SAPROLITE - N/A
		30 to 48	C	weak ABK	1:1	1944 RESTRICTIVE HORIZON - N/A
						1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
2	Linear 10%	0 to 4	L	GR		1942 WETNESS CONDITION - N/A
		4 to 30	C	ABK	1:1	1943/ 1956 SAPROLITE - N/A
		30 to 48	C	weak ABK	1:1	1944 RESTRICTIVE HORIZON - N/A
						1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
3						1942 WETNESS CONDITION -
						1943/ 1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						1942 WETNESS CONDITION -
						1943/ 1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						1942 WETNESS CONDITION -
						1943/ 1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948) PS SITE LONG-TERM ACCEPTANCE RATE: .3
OTHER FACTORS(.1946) _____ SYSTEM TYPE _____
EVALUATED BY: P. C. Moore OTHER(S) PRESENT: Chris Davidson Neil Kale
COMMENTS: _____

DRAFT

0 0 0 0 2 0