IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Pittman DATE 3-21-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Mock Mill Rd. _____ S. R. No. _____


SUBDIVISION NAME Mock Mill Park LOT NO. 120-125 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 20,000 sq ft +

Character & Porosity of Soil Red Clay
Percolation Rate _____
Topography Slight Slope to front Low
Depth to Water Table _____
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Clint Hilliard

IMPROVEMENTS PERMIT BY _____

COMMENTS: Too Much fall from 1st Turn on. Dam used to offset fall. Tank Not Deep enough. Lot to be graded so a Minimum of 6" Cover on Tank.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 3-21-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold