Allie Robertson
Bldr.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR New Bethany Baptist DATE 7/30/79 PERMIT NO. _____

PHONE: Business _____ Home Church Parsonage

LOCATION 64-70 Past Millers Fabric Shop. T.R. into Deer Trail Acres T.R. 1st St. House on Rt _____ S. R. No. _____

SUBDIVISION NAME Deer Trail Acres LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 2 acres


Character & Porosity of Soil Prov Suitable

Percolation Rate _____

Topography Slope Low

Depth to Water Table _____

Rock or other impervious formations Yes - some soft rock in bottom of ditch



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 1176 Linear Ft. 340

Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public (✓)

Installed by Harlee Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: Grade lot so surface water will not stand or run over Septic Tank & lines

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 7/30/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold