## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dale Carpenter DATE 7/18/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70 W. T.R. into Dew Trail just Past Millers Fabric Shop House on Rt at first Street - Corner lot. S. R. No. _____

SUBDIVISION NAME Dew Trail LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

| | | |
|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) |
| Auto. Dishwasher | Yes (✓) | No ( ) |
| Auto. Wash. Machine | Yes (✓) | No ( ) |
| Site Suitable | Yes (✓) | No ( ) |

Lot Area 2½ Acres

Character & Porosity of Soil Prov Suitable
Percolation Rate _____
Topography Steep slope Low
Depth to Water Table _____
Rock or other impervious formations Appox 30' of Site has rock in Bottom



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public ( )

Installed by Hoke Septic Tank

IMPROVEMENTS PERMIT BY _____

COMMENTS: Divert surface water away from tank + lines

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 7/18/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold