DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: David Poole + Carolyn Poole APPLICANT: Jerry Price
ADDRESS: Holmes Rd APPLICATION DATE: 2-2-01 DATE EVALUATED: 2/28/01
PROPOSED FACILITY: 3BR Residence PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 3.61 Acres
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed 300 gpd (225 FT)

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	Linear 4%	0-8	SL gr	NS NP					PS -.4
		8-16	SCL wsbk	SS SP					
		16-35	SCL vwsbk	SS SP					
		35-48	SCL w fgr sbk	SS SP					
2	Linear 4%	0-8	SL gr	NS NP	18" SHW/Ret				PS -.4
		8-16	SCL wsbk	SS SP					
		16-36	SCL vwsbk	SS SP					
		36-48	SCL w fgr sbk						
3	Linear 6% Perc	0-10	SL gr	NS NP					PS -.35
		10-36	SCL wsbk	SS SP					
		36-48	SCL w fgr sbk	SS SP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity 25% Reduc.	Pump 25% Reduc.
Site LTAR	.4	.35

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Thomas
OTHER(S) PRESENT: _____