16009

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Bryan Hooks DATE 5-13-93 PERMIT NO. 8H-A-60

PHONE: Business _____ Home 873-9573

LOCATION I40W TL Old Mtn. Rd. TR Beulah Rd. Stay Straight Mock Mill Rd. Lot on L after 14th house past Iredell Cable. S.R. No. _____

SUBDIVISION NAME NA LOT NO. _____ SECTION OR BLOCK NO. _____

House ☐ Mobile Home ☑ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☐ No ☑

Auto. Wash. Machine Yes ☑ No ☐

Lot Area Ample

Soil Characteristics P.S. Clay


Application Rate .35 gpd/ft²

Topography 2-4% L

Depth to Water Table >4'

Rock or other impervious formations NA

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 1035 Linear Ft. 345'

Depth of Stone in Lines 12"

Water Supply: Individual ☑ Well To Be Located.
Public ☐

Installed by Forest Shuford

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY Michael J. Dennis

COMMENTS Keep Mobile Home 5' from any part of septic system. Keep well min. 50' from any part of septic system. 100% Repair Area below system, conventional, gravity fed.

CERTIFICATE OF COMPLETION BY Michael J. Dennis DATE 5-13-93

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold