DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED:
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Tony & Rhonda Bost OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 1-28-99
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: Mock Mill Rd. Stewart Acres Lot # 28
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY		
1	2-4 % L	0-4"	cl	gR	1:1 / vfr	.1942 WETNESS CONDITION	P.S.
		4"-48"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	NA
						.1944 RESTRICTIVE HORIZON	NA
						.1945 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.35
2	5-7 % L	0-5"	cl	gr	1:1 / vfr	.1942 WETNESS CONDITION	P.S.
		5"-48"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	NA
						.1944 RESTRICTIVE HORIZON	NA
						.1945 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35
3	5-7 % L	0-7"	cl	gR	1:1 / vfr	.1942 WETNESS CONDITION	P.S
		7"-42"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	NA
		42"-↑	c mottles	sbk	1:1/2:1 mix	.1944 RESTRICTIVE HORIZON	NA
						.1945 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35
4	5-7 % L	0-7"	cl	gr	1:1 / vfr	.1942 WETNESS CONDITION	P.S
		7"-44"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	NA
		44"-↑	c mottles	sbk	1:1/2:1 mix	.1944 RESTRICTIVE HORIZON	NA
						.1945 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.35
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1945 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) P.S. SITE CLASSIFICATION (.1945): P.S. SITE LONG-TERM ACCEPTANCE RATE: .35 gpd/ft²
OTHER FACTORS(.1936) SYSTEM TYPE
EVALUATED BY: Michael J. Dennis OTHER(S) PRESENT: Tony & Rhonda Bost
COMMENTS: Install shallow (no deeper than 30" to trench bottom)

DRAFT