DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of ___
PROPERTY ID #: 3794 [illegible]
COUNTY: Wake

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Danny McHargue Jr. APPLICATION DATE: ___
ADDRESS: 114 Marble Vista Stull DATE EVALUATED: 11 Sept. 07
PROPOSED FACILITY: 3bR Home PROPOSED DESIGN FLOW (.1949): 360 gpd PROPERTY SIZE: ___
LOCATION OF SITE: Shannon Trail Lot #30 PROPERTY RECORDED: ___
WATER SUPPLY: • Private • (Public) • Well • Spring • Other ___
EVALUATION METHOD: • (Auger Boring) • Pit • Cut TYPE OF WASTEWATER: • (Sewage) • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LIN 10%	0-8	gr / L	vfr / Ssp					
		8-35	ssbk / C	Fr-fi / Ssp					PS 0.3
		35-48+	mssbk / CL	fr / Ssp	7.5YR	7.5YR	NA	—	
2	LIN 12%	0-6	gr / L	vfr / Ssp					
		6-38	ssbk / C	Fi / Ssp					PS 0.3
		38-48+	mssbk / CL	Fr / Ssp	7.5YR	7.5YR	—	—	
3	LIN 13%	0-6	gr / L	vfr / Ssp					
		6-32	ssbk / C	Fi / Ssp					PS 0.3
		32-48+	mssbk / CL-Ssp	fr / Ssp	7.5YR	7.5YR	—	—	
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	25% Rdc	25% Rdc
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: TLH
OTHER(S) PRESENT: ___

COMMENTS: ___

LEGEND

use the following standard abbreviations

LANDSCAPE POSITION	GROUP	SOIL TEXTURE	CONVENTIONAL .1955 LTAR*	LPP .1957 LTAR*	MINERALOGY/ CONSISTENCE	STRUCTURE
CC (Concave Slope)	I	S (Sand)	1.2 - 0.8	0.6 - 0.4	NEXP (Non-expansive)	G (Single Grain)
CV (Convex Slope)		LS (Loamy Sand)			SEXP (Slightly Expansive)	M (Massive)
D (Drainage Way)					EXP (Expansive)	CR (Crumb)
DS (Debris Slump)	II	SL (Sandy Loam)	0.8 - 0.6	0.4 - 0.3		GR (Granular)
FP (Flood Plain)		L (Loam)				SBK (Subangular Blocky)
FS (Foot Slope)						ABK (Angular Blocky)
H (Head Slope)	III	Si (Silt)	0.6 - 0.3	0.3 - 0.15		PL (Platy)
L (Linear Slope)		SiCL (Silty Clay Loam)				PR (Prismatic)
N (Nose Slope)		CL (Clay Loam)				
R (Ridge)		SCL (Sandy Clay Loam)			**MOIST**	**WET**
S (Shoulder Slope)		SiL (Silt Loam)				
T (Terrace)					VFR (Very Friable)	NS (Non-sticky)
	IV	SC (Sandy Clay)	0.4 - 0.1	0.2 - 0.05	FR (Friable)	SS (Slightly Sticky)
		SiC (Silty Clay)			FI (Firm)	S (Sticky)
		C (Clay)			VFI (Very Firm v. Very Sticky)	VS (Very Sticky)
		O (Organic)	None	None	EFI (Extremely Firm)	NP (Non-plastic)
						SP (Slightly Plastic)
						P (Plastic)
						VP (Very Plastic)

*Adjust LTAR due to depth, consistence, structure, soil wetness, landscape, position, wastewater flow and quality.


NOTES

HORIZON DEPTH	In inches below natural soil surface
DEPTH OF FILL	In inches from land surface
RESTRICTIVE HORIZON	Thickness and depth from land surface
SAPROLITE	S(suitable) or U(unsuitable)
SOIL WETNESS	Inches from land surface to free water or inches from land surface to soil colors with chroma 2 or less - record Munsell color chip designation
CLASSIFICATION	S (Suitable), PS (Provisionally Suitable), or U (Unsuitable)

Evaluation of saprolite shall be by pits.

Long-term Acceptance Rate (LTAR): gal/day/ft^2

Show profile locations and other site features (dimensions, reference or benchmark, and North).



DENR (######)
Review (#####)