IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Sam Morrow DATE 1/12/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Old Mountain Rd. to Neal Sterling Church Rd #1526. T.L. House Lockoff of Rd on Rt approx ¼ Mile beyond Church S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Prob Suitable
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low
			Rock or other impervious formations	None

Lot Area Acreage



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 250 Linear Ft. 250
Depth of Stone in Lines 10" to 12"

Water Supply: Individual (✓)
Public ( )

Installed by Harlen Lackey

Date _____

Rd #1526

IMPROVEMENTS PERMIT BY _____

COMMENTS: Lot to be graded so surface water will run away from septic tank & lines

CERTIFICATE OF COMPLETION BY E. A. Blackwelder DATE 1/12/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold