DEPARTMENT OF ENVIRONMENT, [illegible]
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: ____
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: Silver Wave Prop
ADDRESS: _____ APPLICATION DATE: 1-15-99 DATE EVALUATED: 3-24-99
PROPOSED FACILITY: 3bdrm SW/mH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .55 Ac
LOCATION OF SITE: Lot 4 Feather Sbdvn on Gobble Rd off Island Ford Rd/Iool PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 10%	0-8	SBK/GR SL	FR					PS -3
		8-36	SBK C	FI SS SP					
		36-48	SBK C/SAP	FI SS SP					
2	R 2-3%	0-30	SBK C	FI SS SP					PS .3
		30-48	SBK C/SAP	FI FR					
		48+	SAP						
3	R 2-3%	0-30	SBK C	FI SS SP					PS .3
		30-41	SBK C/SAP	FI FR					
4	H 10%	0-18	SBK C	FI					PS .1
		18-36	MBK C	FI SP					
	B S 8-10%	0-12	SBK SL	FI					PS .25
		12-46	SBK C	FI SS SP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	[illegible]	[illegible]
System Type(s)	[illegible]	[illegible]
Site LTAR	3	.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: C Potter
OTHER(S) PRESENT: _____