DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Julie + Michael Moose APPLICANT: _____
ADDRESS: 157 Westridge Dr Statesville APPLICATION DATE: 10-8-99 DATE EVALUATED: 10-25-99
PROPOSED FACILITY: 3 Bed Dwl PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.10
LOCATION OF SITE: Pearl Rs Exp 31 Old Nortl Rd (L) Cook Island Fs (R) Cul. PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other 266 15th Rd Right
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 8-10%	0-30	SAB C-CL	FR					PS .3
		30-50+	SAB C	SAP/MOD FR					
		50+	C/SAP	MOD PR/FR					
2	L 5.8%	0-18	Plow SCL	V FR	Chroma 2				PS .3 Shallow @ 56" 0-36+ US
		18-36	SAB C	FR					
		36+	C	FR SP SS					
3	L 10%	0-8	Plow SCL		Thin Gray				PS .3
		8-48	SAB C	FR					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	100%	NA
System Type(s)		
Site LTAR	.3	3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Cathy P
OTHER(S) PRESENT: owner