DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: Rockwell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Mayell Eckles — APPLICANT: Piedmont Housing
ADDRESS: ___ — APPLICATION DATE: 3/7/2000 — DATE EVALUATED: 4/14/2000
PROPOSED FACILITY: 3 Bdrm DW — PROPOSED DESIGN FLOW (.1949): 360 — PROPERTY SIZE: 3.70 AC
LOCATION OF SITE: Old Mt Rd Nth (L) Island Ford (L) Cobb (R) Marcus (R) Timberidge — PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other ___ 2nd lot on left
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L-P 2 3%	0-18	G SCL		Red Tan Chroma 2				PS .25
		18-40	SAB^W C	FR SS SP SE-FP					
		40+	C						
2	L-S 3-5%	0-18	G SCL		Tan/Red Brown Chroma 2				PS Shallow .25
		18 36	SAB^W C	FR SS SP SEFP					
		36 48	C	FR					
3	L-R 8-10%	0-10	G SCL						PS -LS
		10-24	SAB^W C	FR SS SP SEFP					
		24+		Chroma 2					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)	Will Need PTS	
Site LTAR	.25	

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: C. Potter
OTHER(S) PRESENT: D. Gaither