DEPARTMENT OF ENVIRONMENT, HEALTH AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: Wadell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: ___ APPLICANT: Clayton Homes
ADDRESS: 2526 Northside DR APPLICATION DATE: 3 29 2000 DATE EVALUATED: 4/8/2000
PROPOSED FACILITY: [illegible] SW PROPOSED DESIGN FLOW (.1949): 450 PROPERTY SIZE: 1.32
LOCATION OF SITE: Lot 16 [illegible] PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other ___ 1st A Turn 2nd Street on Right Corner
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut 1st on Left
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LS 20-25%	0-3	CL						PS .3
		3-30	SBK	C	FR SS SP				
		30-40	SBK	C 1/SP	FR				
		40-52		SP/C					
		52+	SAP						
2	LS 25-28%	0-10			SS SP				PS .3
		10-40	SBK	C 1/SP	FR				
		40-48	SBK	SP/C					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	↘	↘
System Type(s)	25% Ind	50%
Site LTAR	↘	↘

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: [illegible] STR
OTHER(S) PRESENT: [illegible]