DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: Bladen

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: ___ APPLICANT: Freedom Homes
ADDRESS: 1018 Charlotte Hwy, Trenton, NC APPLICATION DATE: 7 12 99 DATE EVALUATED: 7 21 99
PROPOSED FACILITY: 4 Bdrm Rw PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: .81
LOCATION OF SITE: Island Ford (L) Cobbs Rd (L) Kerr Stone Sodom Lane Rd Right Prop on Left Lot 12 PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR. HORIZ	PROFILE CLASS & LTAR
1	L 3-4%	0-12	GR CL	VFR					PS .3+
		12-40	SBK w C/Rl	FR					
		40-48	SBK C/SAP Fm	FR-VFR					
2	L 4-5%	0-20	GR CL	VFR					PS .3
		20-48+	SBK C/LWR	FR SS SP SSP					
		48-	SBK C/SAP Fm	SS SP FR VFR					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: [illegible]
OTHER(S) PRESENT: ___