DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

#097636

OWNER: Silverbrook Properties APPLICANT: Same
ADDRESS: Charlotte, NC. APPLICATION DATE: _____ DATE EVALUATED: 2/23/01
PROPOSED FACILITY: 3BR Mobile PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.14
LOCATION OF SITE: _____ PROPERTY RECORDED: Y
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

Lot # 39

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	Linear 3%	0-11	SC gr	VFr					A 3
		11-24	CL mod	Fi					
		24-54	CL 1/m	Fi					
2	Linear 3%	0-8	SC gr	VFr NS					A 3
		8-38	SC mod	Fi SP SS					
3	12% Ridge Rear	0-11	SC gr	VFr NS					A 3
		11-44	SC sbk	Fi SP SS					
		44+	SC mod	Fi SP SS					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	Y/S	
System Type(s)	Gravity/Conv.	
Site LTAR	3	

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Brian Phillips
OTHER(S) PRESENT: _____