DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Fleetwood Homes APPLICANT: Same
ADDRESS: Moristine APPLICATION DATE: ___ DATE EVALUATED: ___
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.01 A.
LOCATION OF SITE: ___ PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed (Featherstone #58)

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1		0-4	SL						
		4-16	scl						
		16-	Rock						V5
2	5% Linear	0-6	SL	Fr NS NP NEXP					
		6-20	scl	Fr SS SP SEXP					P5 .35
		20-60	cl scl	Fr SS SP SEXP					
3	6% Linear	0-4	SL	Fr NEXP					
		4-10	scl	Fr SEXP					
		10-26	cl	Fi SS SP SEXP					P5 .30
		26-35	C	Fi SP SEXP					
		35-45	cl	Fi					
4	7½% Linear	0-4	SL	NEXP					
		4-9	scl	VFr SS SP SEXP					P5 .35
		9-41	cl scl	Fi SS SP SEXP					
		41-49	scl	Fr NS NP NEXP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	100%	100%
System Type(s)	3	35
Site LTAR	Evap Clay	Comp 25% Red

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: ___