10336. Kelsey Edward in Terminal

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR BRUCE HAMMON DATE 8-18-92. PERMIT NO. 8V-A-31.

PHONE: Business _____ Home _____

LOCATION New Sterling Rd. off Old Mtn. Rd. - T.R. on Linda Loop - T.R. on Belick Rd. - go ¼ mi. on (R). Enter dirt rd. - go to end on (R).

SUBDIVISION NAME _____ LOT NO. LOT I. SECTION OR BLOCK NO. _____ S.R. No. _____

House ✓ Mobile Home [ ] Business [ ] Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes [ ] No [ ]

Auto. Dishwasher Yes [ ] No [ ]

Auto. Wash. Machine Yes [✓] No [ ]

Lot Area Ample.

Soil Characteristics Prov. Suitable.


Application Rate .4 gal./sq. ft.

Topography 2 - 6%

Depth to Water Table 10'+

Rock or other impervious formations None observed.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement _____ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual ✓

Public ☐

Installed by Tommy Cothren

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY Steve Brown

COMMENTS System started on 8-7-92 but rained out.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 8-18-92.

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold