# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Walker DATE 3-8-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-40 W. To Old Mountain Rd. T. R. Go To Bressly Farm Road Rd # 1534 - Go about ½ Mile. Trailer on L.


SUBDIVISION NAME _____ S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

| | | | | |
|---|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | Character & Porosity of Soil | Red Clay |
| Auto. Dishwasher | Yes ( ) | No (✓) | Percolation Rate | 16 Perk Test |
| Auto. Wash. Machine | Yes (✓) | No ( ) | Topography | Slight Slope |
| Site Suitable | Yes (✓) | No ( ) | Depth to Water Table | Low |
| Lot Area Acreage | | | Rock or other impervious formations | None |



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 630 Linear Ft. 252

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Alexander Septic Tank Co.

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: Layout Changed. Owner Changed mind.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 3-8-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold