IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dana L. Porter DATE 10-25-73 PERMIT NO. _____

PHONE: Business _____ Home 585-6984

LOCATION Old Mountain Rd. to approx. 4½ miles West of I-40 T.L. on Rd 1534. Trailer at Farm Pond on L. S. R. No. 1534


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area Acreage

Character & Porosity of Soil Red Clay
Percolation Rate No Perk Test Made
Topography Sloping toward Pond Lot
Depth to Water Table _____
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 562½ Linear Ft. 225
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Harlie Lackey

IMPROVEMENTS PERMIT BY E. G. Stevenson

COMMENTS: Water from Deaton House. Trailer Not on lot at time of inspection

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 10-25-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold