IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bill Dancy DATE 4/10/80 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Old Mt Rd above Bradford X Rd, T.L. on New Sterling Ch. Rd, T.R. on drive ¼ mile before church S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2 ✓

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Poor Suitable
Percolation Rate _____
Topography slope
Depth to Water Table low
Rock or other impervious formations none around

Lot Area acreage



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Herbie Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: This ~~system~~ tank size not designed for garbage grinder

CERTIFICATE OF COMPLETION BY Andrew E. Causey & Billie W. Johnson DATE 4/16/80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold