DAVID BRADY

4.00 Wes Lytton

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 079433 PIN# 3795 40 0191 DATE 3-9-99

OWNER OR CONTRACTOR NEW STERLING A.R.P. CHURCH PHONE: Business 872-5370 Home

ADDRESS 580 NEW STERLING ROAD, STATESVILLE, NC 28677

LOCATION I-40 W, TR OLD MTN. ROAD, TL NEW STERLING CH. ROAD, ON LEFT AT BOX # 580

SUBDIVISION BLOCK / SECTION LOT LOT AREA 11.50 ACRES SITE CLASS PS DESIGN FLOW 720 L.T.A.R. 0.25 GPD/FT²

Septic Tank: 1500 Gallons; STB 358 Date 10/6/00

GREASE TRAP 1000 Gallons; GSD 794 Date 10/2/00

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet EQ. TO 2880 Linear Feet 720+

No Lines SIX Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth SAND 6"

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: 25% REDUCTION SYSTEM

Repair System Description: MAX. FEASIBLE - 25%

Maintenance Agreement Required: ☐ Yes ☑ No

☐ House/Mod. Home No. Bedrooms —

☐ Mobile Home No. Bathrooms 5

☐ Business No. Employees —

☑ Other CHURCH @ 344

☐ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☑ Public ☐ Community WELL

Comments/Conditions: INSTALL 25% REDUCTION SYSTEM USING 120 CHAMBERS OR 72 H.D.S. SECTIONS IN SIX EQUAL LENGTH LINES ON CONTOUR

Comments/Conditions:

INITIAL SITE SKETCH

SEE ATTACHED SITE PLAN

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: David F Brady date 3-12-99 Installed by: Wes Lytton

Improvement Permit by: STEVE HEDRICK date 3-9-99 Operation Permit by: RSI date 11/27/00

Authorization to Construct by: STEVE HEDRICK date 3-9-99 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK