DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jenkins & Williams Const. APPLICANT: Same
ADDRESS: _____ APPLICATION DATE: 3/10/01 DATE EVALUATED: 4/9/01
PROPOSED FACILITY: 3BR 2BA PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: _____
LOCATION OF SITE: Stoneydell # 11 PROPERTY RECORDED: X
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Stoneydell Lot #11

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	5% Linear	0-6	Scl SBK	SS SP SE					PS .3
		6-42	cl fr Zone SBK	S P SE					
		42-48	cl Sandy inc SBK	S P SE					
2	5% Linear	0-10	Scl w SBK	SS SP SE					PS .3
		10-29	cl SBK	S P SE					
		29-36	cl w/ Sap frags SBK	SP SE					
		36-48	cl w many saprock SBK	SS SP					
3	6% Linear	0-8	Scl w S	SS SP SE					PS .3
		8-32	cl w SBK	S P SE					
		32-42	cl U Sap	S P SE					
		42-49	cl U many saprock	SS SP SE					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	125	125
System Type(s)	Gravity Conv.	Gravity Conv.
Site LTAR	.35	.35

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____