## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Sanford Kurfees DATE 11/22/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Old Mountain Rd. Above Bradford's X Rd. T.L. 1st Rd Above Stewarts Garage - T.R. House on L. at Curve S. R. No. _____

SUBDIVISION NAME West Iredell Site LOT NO 152-172 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 3½ Acres

Character & Porosity of Soil Cecil Clay
Percolation Rate _____
Topography Slope
Depth to Water Table Low
Rock or other impervious formations None




Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: Surface water needs to be diverted away from Septic Tank + lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 11/22/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold