1 - ~

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jenkins Building Co DATE 2-18-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I 40 W - T R on Old Mountain Rd. Tk. 1st Road Past Stewarts Garage. Turn Back to R. House on R 4th from End R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

Job # 33

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area _____


Character & Porosity of Soil Red Clay

Percolation Rate No Perk Test

Topography Slight Slope to front

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 630 Linear Ft. 252

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Jenkins Bldrs

IMPROVEMENTS PERMIT BY E. G. Stevenson

COMMENTS: House under Construction Prior to Sept 1, 1973

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 2-18-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold