IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jenkins Bldg. Co DATE 7-9-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-40 W. T.R. on old Mountain Rd. T.L. 1st Rd Past Stewart Garage Bear back to R. House on R. 3rd from end of Street S. R. No. _____

SUBDIVISION NAME _____ LOT NO. Jot #32 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area _____

Character & Porosity of Soil Red Clay
Percolation Rate No Perk Test
Topography Slight Slope to Front
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 630 Linear Ft. 252
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Jenkins Bldg. Co

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: House under Construction Prior to Sept 1, 1973

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 7-9-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold