## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bro DATE 10/25/78 PERMIT NO.

PHONE: Business Home

LOCATION Old Mountain Rd. Above Stewarts Garage - T.L. on #1530 1st House on L. at RD#1580

SUBDIVISION NAME West Iredell Sites LOT NO. 27 SECTION OR BLOCK NO. S. R. No.


House (+) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1 1/2

| | | |
|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (+) |
| Auto. Dishwasher | Yes ( ) | No (+) |
| Auto. Wash. Machine | Yes (+) | No ( ) |
| Site Suitable | Yes (+) | No ( ) |

Lot Area 20 000 Sq ft

Character & Porosity of Soil Prod Suitable
Percolation Rate
Topography 2% Slope
Depth to Water Table Low
Rock or other impervious formations None




Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (+)

Installed by Hope Bro

IMPROVEMENTS PERMIT BY

COMMENTS:

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 10/24/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold