IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bro DATE 9/19/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-40 W. T.R. on Old Mountain Rd. Go aprox 2 1/10 Mile House on L at Corner of Old Mt. Rd and Rd# 1520 S. R. No. _____

SUBDIVISION NAME West Iredell Sites LOT NO. 3 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 20 000 Sq ft

Character & Porosity of Soil Prov Suitable
Percolation Rate _____
Topography 2- 6%
Depth to Water Table Low
Rock or other impervious formations None

2631 # 81



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Hope Bro

IMPROVEMENTS PERMIT BY _____

COMMENTS: Water from downspout should be diverted away from Tank & Line

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 9/14/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold