IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / CERTIFICATE OF COMPLETION / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PROPERTY DESCRIPTION NO. 25172 DATE 12-7-96 TAX MAP NO. Pt 84 - A - 76 Watershed: ☐ Yes ☑ No

OWNER OR CONTRACTOR Clyde Itall PHONE: Business 585-2728 Home

ADDRESS PO Box 1556 mooresville

LOCATION Off mtn Rd TR Lindsey Fm Rd TR Barkeylin Th millet 1st lot left

SUBDIVISION Lindsay Fm BLOCK / SECTION LOT 21 LOT AREA .717 acres SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 1012 Date 8-26-97 ☑ New System ☐ Repair System Type: I, II, III IV, V, VI

Pump Tank: Gallons; PT Date System Description: conv

Pump Make: Model Serial No. Repair System Description: Gravity chambers

Nitrification Field: No Fields 1 Square Feet 900 Linear Feet 300 Maintenance Agreement Required: ☐ Yes ☑ No (Panels)

No Lines 5 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth ☐ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☐ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Bathrooms 2

☐ Business No. Employees

☐ Other

Water Supply: ☑ Individual ☐ Community ☐ Public

Comments:

* Area was cut more than one ft - changed line

Comments:

INITIAL SITE SKETCH

Barkley Lane

Drive

50'

3x90' 3x80' 3x70' 3x60' 3x50'

3x20'

2 @ 160' max

S.T.

10'

Dist box 250'

Repair

Millet

120'

AS BUILT SKETCH

Length Added 5th Line

40'

well site

15'

* Installed as shown

well

Rock

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit is valid for 60 months from date of issuance.

Signed: [signature]

Improvement Permit by: R. C. Moore date 12-7-96

Existing System Inspection by: R. C. Moore date 12-7-96

Authorization to cover

Installed by: Kenny Madison

Certificate of Completion by: date

Operation Permit by: [signature] date 11-24-97

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD

Authorization to Cover Expires 6 mos from issue