HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Gladdys Blevins OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 9-7-94
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: Lackey Farm Rd
WATER SUPPLY: On-Site Well Comm. Well Public / Other EVAL. METHOD: Auger Boring / Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
5	3-10% L	0-3"	l	gr	fr	.1942 WETNES CONDITION	- S
		3"-18"	c	Abk	fr	.1943/.1956 SAPROLITE	- 20" U
		18"-20"	c/sap	Abk/m	fi	.1944 RESTRICTIVE HORIZON	- NA
		20" +	sap.	m	fr	.1948 PROFILE CLASSIFICATION	- U
						PROFILE LTAR	-
6	8-10% L	0-4"	cl	Abk	fr	.1942 WETNES CONDITION	- S
		4"-37"	c	Abk	fr	.1943/.1956 SAPROLITE	- 42" P.S
		37"-42"	c/sap	Abk/m	fi	.1944 RESTRICTIVE HORIZON	- NA
		42"-48"	sap.	m	fr	.1948 PROFILE CLASSIFICATION	- P.S
						PROFILE LTAR	- .35
7	3-5% L	0-5"	cl	gr	fr	.1942 WETNESS CONDITION	U - 1 Chroma II
		5"-37"	c	Abk	chroma II	.1943/.1956 SAPROLITE	- 37" P.S
		37"-48"	c/sap.	Abk/m	chroma II	.1944 RESTRICTIVE HORIZON	- NA
						.1948 PROFILE CLASSIFICATION	- U
						PROFILE LTAR	-
8	3-5% L	0-7"	cl	Abk	fr	.1942 WETNESS CONDITION	- U mixed 2:1
		7"-30"	c	Abk	fr	.1943/.1956 SAPROLITE	- NA
		30"-48"	c	Abk	mixed 2:1	.1944 RESTRICTIVE HORIZON	- NA
						.1948 PROFILE CLASSIFICATION	- U
						PROFILE LTAR	-
9	5-7% L	0-5"	cl	gr	fr	.1942 WETNESS CONDITION	- S
		5"-33"	c	Abk	fi	.1943/.1956 SAPROLITE	- 38" P.S.
		33"-38"	c/sap	Abk/m	fi	.1944 RESTRICTIVE HORIZON	- NA
		38"-46"	sap-	m	fr	.1948 PROFILE CLASSIFICATION	- P.S
						PROFILE LTAR	- .35

AVAILABLE SPACE (.1945) SITE CLASSIFICATION (.1948): SITE LONG-TERM ACCEPTANCE RATE:
OTHER FACTORS(.1948) SYSTEM TYPE
EVALUATED BY: Michael Denning OTHER(S) PRESENT: Mr. & Mrs. Blevins.
COMMENTS: Owners ask for second opinion on lower part of lot

DRAFT