HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

(4)

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Gladdys Blevins OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 9-12-94
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: Lackey Farm Rd
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
14	6-9% L	0-4"	cl	gr	vfr	.1942 WETNES CONDITION - S
		4"-30"	c	sbk	fi	.1943/.1956 SAPROLITE - 39" PS
		30"-39"	c/sap	wsbk/m	fi	.1944 RESTRICTIVE HORIZON - NA
		39"-45"	sap	m	fr	.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
15	8-10% L	0-5"	cl	gr	vfr	.1942 WETNES CONDITION - S
		5"-37"	c	sbk	fr	.1943/.1956 SAPROLITE - 35
		37"-48"	c/sap	wsbk/m	fr	.1944 RESTRICTIVE HORIZON - NA
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) 5 SITE CLASSIFICATION (.1948): PS. SITE LONG-TERM ACCEPTANCE RATE: .35 gpd/ft²
OTHER FACTORS(.1946) SYSTEM TYPE Conventional gravity fed
EVALUATED BY: Michael Dennis OTHER(S) PRESENT: Second opinion performed on 9-8-94 by J.C. Moore
COMMENTS: Relocated site for home as close to back property line as possible to utilize only area for septic system without pumping.

DRAFT