09608

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR EARL JENKS DATE 3-16-89 PERMIT NO. 98

PHONE: Business _____ Home _____

LOCATION Hwy 90 W. Stony Point T.L. on Lackey Farm Rd. - go approx. ½ mi. T.R. on Emerald Lane - 1st lot on left. S. R. No. _____


SUBDIVISION NAME GREEN VALLEY DEV. LOT NO. 3 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2 Character & Porosity of Soil Loam - Suitable.
Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate 1" / 30 min.
Auto. Dishwasher Yes (✓) No ( ) Topography Level
Auto. Wash. Machine Yes (✓) No ( ) Depth to Water Table 10'+
Site Suitable Yes (✓) No ( ) Rock or other impervious formations None observed

Lot Area .87 acres.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 120 Linear Ft 240
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Plot of System

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Do not park or drive over S.T. system.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 3-20-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold