10333.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR DEAN DISHMAN DATE 8-21-89 PERMIT NO. 9EH-A-17

PHONE: Business _____ Home _____

LOCATION Hwy 90W to Stacy Point-T.L. on Lackey Farm Rd-approx. ¼ mi. on R


SUBDIVISION NAME GREEN VALLEY DEV. LOT NO. 17 S. R. No. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil Loam - Suitable.
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate 60 Min/In
Auto. Wash. Machine	Yes (✓)	No ( )	Topography Gently Sloping
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 10 Ft+
Lot Area .74 acres			Rock or other impervious formations Not encountered.

_____ Basement with Plumbing 1 Basement without Plumbing _____ No Basement



Size of Tank 1000 Gals.
Nitrification Field: 2
No. of Lines 2
Sq. Ft. 400 Lineal Ft. 220
Depth of Stone in Lines 1 Ft.
Water Supply: Individual ( )
Public (✓)

Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Plot of System

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 8-21-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold