IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / CERTIFICATE OF COMPLETION / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PROPERTY DESCRIPTION NO. 069600 DATE 10-8-97 TAX MAP NO. 3797 52 9275 Watershed: ☐ Yes ☒ No

OWNER OR CONTRACTOR ORTEGA TATUM PHONE: Business _____ Home 871-9446

ADDRESS 357 WESTWOOD DRIVE, STATESVILLE, NC 28677

LOCATION NC 90 W TL W. LACKEY FARM RD, TR PLANK BARN ROAD, 1ST LOT ON RIGHT

SUBDIVISION STONY HILLS BLOCK / SECTION _____ LOT 311 LOT AREA 1.0348 ACRES SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. 0.25 GPD/FT²

Septic Tank: 1000 Gallons; STB 794 Date 9-18-97

Pump Tank: _____ Gallons; PT _____ Date _____

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 1 Square Feet 1440 Linear Feet 480

No Lines 3 1X Trench Width 36" Max Trench Bottom Depth 30" Gravel Depth 12"

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: CONVENTIONAL GRAVITY

Repair System Description: CONV. GRAVITY

Maintenance Agreement Required: ☐ Yes ☒ No

☐ House/Mod. Home ☑ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Bathrooms 2 No. Employees ____

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☐ Community ☒ Public

Comments: ① INSTALL SUBSURFACE INTERCEPT DRAINAGE DITCH AS SHOWN BEGINNING 42" DEEP W/ FALL OUT TO DAYLIGHT ② USE ONE FLOW DIVERTER TEE TO ACHIEVE EQUAL DISTRIBUTION INTO EACH OF TWO DIST. BOXES FEEDING THREE LINES EACH.

Comments: INTERCEPT DITCH DRAINS TO LEFT RATHER THAN RIGHT SIDE OF LOT TO AVOID UNDERGROUND POWER LINE

INITIAL SITE SKETCH SCALE: 1" = 50'



AS BUILT SKETCH

SYSTEM INSTALLED ACCORDING TO INITIAL SITE SKETCH

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit is valid for 60 months from date of issuance. AUTHORIZATION TO CONSTRUCT IS VALID FOR 60 MONTHS FROM DATE OF ISSUANCE.

Signed: X Ortega Tatum

Improvement Permit by: STEVE HEDRICK date 10-8-97

AMD-TO CONST. Existing System Inspection by: STEVE HEDRICK date 10-8-97

Installed by: ACE CONTRACTING (CATAWBA CO.)

~~Certificate of Completion by:~~ _____ date _____

Operation Permit by: STEVE HEDRICK date 12-5-97

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD

19620