IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

REPAIR

OWNER OR CONTRACTOR HARVEY LEVAN DATE 7/17/91 PERMIT NO. REPAIR

PHONE: Business _____ Home _____

LOCATION NC 90 W, TR AT ALEXANDER CO. LINE, TR HALYBURTON RD, 2ND HOUSE ON (L)

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other REPAIR


No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes (✓)	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area AMPLE

Character & Porosity of Soil DS
Percolation Rate .4 GAL / FT²
Topography ~4-6% LS
Depth to Water Table 3-4'
Rock or other impervious formations NONE

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank EXISTING Gals.
Nitrification Field:
No. of Lines 1
Sq. Ft. 360 Linear Ft. 120
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by TOMMY COTHREN

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HENDRICK

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HENDRICK DATE 7/17/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold