IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hagen Trailer Park DATE 8-29-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy # 90 - Trailer Park on L Near Alexander County Line S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (1) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area 20,000 Sq ft

Character & Porosity of Soil Cecil Clay
Percolation Rate _____
Topography Slope to rear
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1250 Linear Ft. 500
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (1)

Installed by Lackey Bro

IMPROVEMENTS PERMIT BY _____

COMMENTS: Small stream to be diverted into New Ditch before Trailers are moved on Lot.

CERTIFICATE OF COMPLETION BY E. A. Stutzenson DATE 8-29-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold