DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Dale Stikeleather APPLICANT: Same
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 1/19
PROPOSED FACILITY: 3BR mH Home PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: ___
LOCATION OF SITE: ___ PROPERTY RECORDED: N.
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Lot #2

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	7% Linear	0-7	SL g	NS NP VFr					PS .35
		7-11	SaL wSbk	VFr SS SP SEP					
		11-27	SCL SBk	Fr SS SP SEP					
		27-44	cSCL Some Ca	Fr SEP					
		44-48	cSCL W Mangan SAP	NEP					
2	8% Linear	0-8	SL g	NS NP VFr					PS .35
		8-16	SCL GSBK	VFr SS SP SEP					
		16-29	CL SBK	Fr SS SP SEP					
		29-40	cSCL Some Mn	Fr SS SP SEP					
		40-48	cSCL Few Mangan SAP	NS VP VSP					
3	13% Linear	0-4	SL g	NS NP NEP					PS .35
		4-12	SCL wSBk	Fr SS SP SEP					
		12-40	CL SBk	Fr SS SP SEP					
		40+	cSCL WSAP Some Mn	Fr SS NP SEP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv. Conv.	Conv. Conv.
Site LTAR	.35	.35

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: B. A. Johnson
OTHER(S) PRESENT: ___