DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Johnnie Morrison APPLICANT: -Ad (Ridge Pd mobile Homes
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 4/19
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 240 PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

(269 FF) 3/8000 6 Soil

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	6% Linear	0-7	scl	fr SS SP SEXP	26 BRN/gray mottles 32" BRN Yellow Red mottles				PS .3
		7-18	cl	fr/fi SS SP					
		18-48	c	fi SS SP					
2	7% Linear	0-11	scl	fr SEXP	20" few BRN/yellow mott				PS .25
		11-17	cl	fr/fi					
		17-38	c	fi S P					
		38-48	cl	fr SS SP SEXP					
3	Linear	0-11	scl	fr SS SP	20" BRN Yellow mottled				B .25
		11-18	cl	fr/fi SS SP					
		18-37	c	fi SP SEXP					
		37-48	cl	fr SS SP SEXP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Trench Conv.	Trench 25%
Site LTAR	.25	.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____