11350.

36789

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR STEVEN ELLER DATE 9-25-90 PERMIT NO. 9J-B-90

PHONE: Business _____ Home _____

LOCATION Hwy 90W-90 9 miles past Scotts School-T.L. on gravel drive between Two Lanes-90 & Enos

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 3.32 acres.

Character & Porosity of Soil Pre-Suitable.
Percolation Rate 20 min/in
Topography 2-15%
Depth to Water Table 18+
Rock or other impervious formations none observed.

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12

Water Supply: Individual ( )
Public (✓)

Installed by Mike Holland

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Plot of System

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 9-15-90.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold