Date Issued 14 June 1976

Serial No. 7590

ICAR (S) Permit No. 10939

T C No 001-2H-42

Map Date 2-21-75


# MECKLENBURG COUNTY HEALTH DEPARTMENT

## ENVIRONMENTAL HEALTH DIVISION

### INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT

**(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)**

Permission is hereby given to ~~Install~~ or Construct ~~Alter~~ or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 10939, dated 6-2-76 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 12 July 76 after which date this permit shall be null and void




PLOT OF SYSTEM

Percolation Rate 60

Liquid Capacity of Tank 1500

Tank Construction pre cast

Absorption and/or Nitrification Lines

Total Line Length 450

Number of Lines 5

Distance from House 10'

Distance from Property Line 10' +

Distance from Well 50' +

NAME OF OWNER Hayyard, Robert R.

LOCATION OF PROPERTY Tuskarora Trail Lot 224

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments: in bed 12½ x 45' x 36" ~~#~~ 10 stone

John R. Knisson

Director or Section Head

Environmentalist

If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired

FORM NO. E-5-4-2M-6-75

**HEALTH DEPARTMENT COPY**